

PROVA DI PORTATA VENTILATORE ASSIALE

AIRFLOW TEST FOR AXIAL FAN

| | | | |
|-----------------------------|---|------------------------------------|------------------|
| Tipo - Type | Tensione di Prova <i>Test Voltage</i> | N° Prova <i>Test No.</i> | N° Progr. |
| VA14-AP8/C-34A | 13 V. CC. - DC. | 361-04 | 3854 |
| Note <i>Notes</i> | | | |

| Pressione Statica <i>Static Pressure</i> <i>mmH2O</i> | Portata <i>Airflow</i> <i>m³/h</i> | Corrente Assorbita <i>Current input</i> <i>A</i> |
|--|--|---|
| 0,1 | 525 | 3,7 |
| 2,6 | 468 | 3,8 |
| 4,9 | 410 | 3,8 |
| 7,4 | 329 | 3,9 |
| 10,0 | 243 | 3,9 |
| 12,5 | 175 | 4,2 |
| 15,0 | 98 | 4,1 |
| 16,5 | 0 | 4,1 |

| | |
|-------------|-------------------------|
| Note | <hr/> <hr/> <hr/> <hr/> |
|-------------|-------------------------|